Fisher[™] FIELDVUE[™] DVC6200 and DVC6200f Digital Valve Controllers

Table of Contents

Management of Change	.2
Background	.2
Question & Answer Checklist	.2
Comparison of DVC6000 and DVC6200 Instruments	.4
DVC6000 to DVC6200 Instrument Transition Design Comparison	.7
Electrical	7
Position Control Capabilities	8
Diagnostic Capabilities	9
Operating Ambient Temperature Limits	9
Steady-State Air Consumption	9
Maximum Output Capacity	9
Connections	9
Available Configurations	10
Conclusion	10
Additional Resources	11





Management of Change

Management of Change (MOC) is a procedure used to proactively manage changes that have the potential to impact safety or the process within a plant. Evaluating new techniques for improving MOC approval procedures can have an impact on plant efficiency. Historically, upgrading obsolete products or replacing existing process control equipment had been delayed or abandoned due to the extensive paperwork involved in completing a complex MOC approval sheet.

Background

The Fisher FIELDVUE DVC6000 series of digital valve controllers have proven to be the most reliable digital valve controllers produced. Today, the introduction of the DVC6200 and DVC6200f marks a step change in the technology, which will further improve the reliability of these instruments in the harshest environments. This step change in technology was made possible by utilizing the proven modular technology of the one million and counting existing DVC6000 units in the field today.

The design philosophy of the DVC6200 and DVC6200f allows the user the flexibility to transition from legacy FIELDVUE products to the current DVC6200, avoiding lengthy management of change approval documents. This document will highlight the design of the DVC6200 and DVC6200f, which incorporates linkage-less, non-contact feedback technology into an intrinsically safe and explosion-proof package. This feedback technology has been field-proven in the DVC2000 since 2004 in high vibration and corrosive environments. Over 73,000 FIELDVUE DVC2000 instruments have been installed with no failures of this feedback technology.

Displayed in the following sections are design comparisons between the current DVC6200 and legacy DVC6000 products. These comparisons demonstrate how the design of Fisher technologies allows users to efficiently transition to new, more reliable FIELDVUE products.

Question & Answer Checklist

- **1 Q:** Does the proposed modification cause any changes to the piping and instrumentation diagram (P&ID)?
 - A: Only the instrument name changes from DVC6000 to DVC6200.
- **2 Q:** Does the proposed modification change process chemistry, technology, or operating and control philosophies?
 - A: No.

- **3 Q:** Have the operating and design limits of the proposed modification changed?
 - **A:** No.
- **Q:** Have the codes and standards to which the new equipment has been designed changed?
 - A: No.
- **5 Q:** Does the proposed modification change the Hazardous Electrical Area classification?
 - **A:** No.
- 6 Q: Does the proposed modification change existing or create new demands for battery back-up or other power supply redundancy or reliability?
 - A: No.
- **7 Q:** Does the proposed modification introduce new equipment that needs to be operated and, has a new operations list been stated?
 - A: Yes. The DVC6200 and DVC6200f are operated the same as the DVC6000 and DVC600f.
- 8 Q: Does the proposed modification introduce new equipment items that require spare parts, training manuals, maintenance procedures or training to teach the maintenance department how to maintain them?
 - A: Yes. The standard components that maintenance may be required on are the same between the old and new equipment, except for the differing feedback technology. The mounting methodology also varies between the old and new technology.
- **9 Q:** Does the proposed modification change the spares for existing pieces of equipment?
 - **A:** No.

- **10 Q:** Does the proposed modification introduce new equipment items that require periodic predictive maintenance?
 - A: No. The new equipment items that may require periodic maintenance are the same as the old equipment items, except for the position feedback element. The new position feedback element (magnet / hall effect sensor) requires no maintenance where the old feedback element was a potentiometer that required periodic evaluation to confirm no mechanical issues were present.

Comparison of DVC6000 and DVC6200 Instruments

The DV6200 with HART[®] communication uses the same internal components, electronics and covers as the DVC6000. This is detailed below in Table 1. The DVC6000 uses a potentiometer to obtain position feedback, whereas the DVC6200 position feedback utilizes a Hall effect sensor and magnetic array. This is the same technology as used in the DVC2000. The DVC2000 was the first Fisher instrument released by Emerson that used a Hall effect sensor and a magnet array to measure valve travel. The Hall effect sensor is located in the DVC6200 housing between two "pole pieces" that are used to sense the magnet flux field of a magnetic array. The magnet array is mounted to the valve stem. As the valve stem moves, the magnet array also moves (relative to the sensor). The magnet array is composed of a series of magnets of different strengths, so the sensor can measure the changing magnetic field. Since there are no touching parts, this feedback is completely noncontact and does not rely on linkages.

DVC6000 or DVC6000f Component	DVC6200 and DVC6000	DVC6200f and DVC6000f	
I/P	No change	No change	
Relay	No change	No change	
Printed Wiring Board	No change	New	
Term Box	No change	No change	
Cover	No change	No change	
Mod Base	No change	No change	
Back Housing	New	New	
Mounting	New	New	
Position Feedback	DVC2000 Technology	DVC2000 Technology	
Firmware	No change	New	

Table 1. FIELDVUE DVC6000 and DVC6200 Instrument Component Comparison

Description	DVC6200 vs. DVC6000DVC6200f vs.Remote Mount HARTDVC6000f Remote Mount			
Base Unit	DVC6205 vs. DVC6005	DVC6205f vs. DVC6005f		
I/P	No Change	No Change		
Relay	No Change	No Change		
Printed Wiring Board	No Change	New		
Loop Term Box	No Change	No Change		
Field Termination Term Box	New	New		
Cover	No Change	No Change		
Module Base	No Change	No Change		
Back Housing	No Change	No Change		
Firmware	No Change	New		
Remote Travel Feedback Unit	New	New		
Position Feedback	DVC2000 Technology	DVC2000 Technology		
Wiring between remote and base unit	Needs to be housed in flexible or rigid metal conduit.			

Table 2. FIELDVUE DVC6000 Remote Mount and DVC6200 Remote Mount Component Comparison




Figure 1. DVC6000 and DVC6200 Instrument Assembly Comparison

The DVC6200 and DVC6200f will utilize a new back housing and mounting as is illustrated in Figures 2 and 3 shown on the subsequent pages. The potentiometer of the DVC6000 is removed from the back plane and replaced with a Hall effect sensor that is potted into the new DVC6200 housing design. The terminal box moves to the left of the instrument in the DVC6200 (when viewed from front); this allows for a tighter fit with small actuators and integral mount actuators like the Fisher GX actuator.

The fieldbus version of the new 6200f features a new printed wiring board and firmware required to transition to a universal Emerson microprocessor platform. This microprocessor is designed by Emerson and is manufactured exclusively for the various Emerson divisions. All Emerson divisions having fieldbus devices use this processor; this provides consistent behavior and functionality among all Emerson divisions. This product change will include the following improvements to the DVC6200f instrument:

Back-up LAS - Every fieldbus segment has a link active scheduler (LAS). There is also a designated device that will act as the backup LAS if the primary LAS were to become unavailable. The DVC6200f has the ability to act as the back-up LAS.

Faster block execution - Faster block execution allows the user to schedule a faster macro cycle (better control) and an increased number of loops per segment (reduced wiring).




Figure 2: DVC6000 Instrument Housing Detail



Figure 4: DVC6000 Remote Mount




Figure 3: DVC6200 Instrument Housing Detail




Figure 5: DVC6200 Remote Mount

DVC6000 to DVC6200 Instrument Transition Design Comparison

Electrical

No change to IS entity parameters (see Figures 6–9).






NATURAL GAS APPROVED BAGLE BEAL DRIVCE MAX SEAL PRESS: 145 PGI SEAL TEMP: -52°C TO 85°C CONDITION NOT TO EXCEED MAIN NAMEPLATE RATING

LABEL FOR NATURAL GAS CERTIFIED TERMINAL BOX

Figure 7. DVC6200 Instrument FM Approvals Nameplate



(c) prostruct provers branspulle size cause we seek cause his in less for one one

TO LODA WAT IN COMMENTED ACCOMPANY TO THE BARREN MAAR WEILARD HAR WEILARD

[7] P HARPHELD CONTRACTOR OF PLATFULXION IS USED IF PLATING WAVEFULX WITH DESIGN PLANETERS AND REPORTED PER THE INSURACTIVENES CONTRACTORIES.

Figure 8. FM Schematic for DVC6010, DVC6020, and DVC6030 Instruments




Figure 9. FM Nameplates for DVC6010, DVC6020, and DVC6030 Instruments

The DVC6200 Remote Mount does not have any third party hazardous area approvals yet.

Position Control Capabilities

- a. Accuracy = ± 0.55% of output span
- b. Hysteresis = ± 0.325% of output span
- c. Deadband = < 0.125% of output span

Diagnostic Capabilities

No change (see Table 3).

Diagnostic Level			
AC	HC or FD	AD	PD
Х	Х	Х	Х
Х	Х	Х	Х
	Х	Х	Х
	Х	Х	Х
		Х	Х
		Х	Х
		Х	Х
			Х
	V	AC HC or FD X X X X X X X X	AC HC or FD AD X X X X X X X X X X X X X X X X X X X X X X X X

Table 3. FIELDVUE DVC6200 and DVC6200f Instrument Diagnostic Level Capabilities

Operating Ambient Temperature Limits

No change:

- -40° to 85°C (-40° to 185°F)
- -52° to 85°C (-62° to 185°F) for instruments utilizing the extreme temperature option (fluorosilicone elastomers)
- -52 to 125°C (-62 to 257F) for remote mount feedback unit

Steady-State Air Consumption

No change:

- At 1.4 bar (20 psig) supply pressure: less than 0.38 normal m3/hr (14 scfh)
- At 5.5 bar (80 psig) supply pressure: less than 1.3 normal m3/hr (49 scfh)

Maximum Output Capacity

No change:

- At 1.4 bar (20 psig) supply pressure: 10.0 normal m3/hr (375 scfh)
- At 5.5 bar (80 psig) supply pressure: 29.5 normal m3/hr (1100 scfh)

Connections

No change:

Supply pressure: 1/4 NPT internal and integral pad for mounting 67CFR regulator

- Output pressure: 1/4 NPT internal
- Tubing: 3/8-inch recommended
- Vent (pipe-away): 3/8 NPT internal
- Electrical: 1/2 NPT internal conduit connection

Available Configurations

 Available configurations change from three (3) configurations DVC6000 instrument to one (1) configuration DVC6200 instrument, reducing user inventory

i. DVC6000 valve-mounted instrument:

- 1. DVC6010 instrument: Sliding stem applications
- 2. DVC6020 instrument: Rotary applications and long stroke sliding stem applications.
- 3. DVC6030 instrument: Quarter-turn rotary applications
- ii. DVC6200 valve-mounted instrument:
 - 1. DVC6200: Sliding stem, rotary, quarter-turn rotary applications
- Available configurations change from three (3) configurations DVC6000 remote mount instrument to one (1) configuration DVC6200 remote mount instrument, reducing user inventory
 - i. DVC6000 remote travel feedback sensor:
 - 1. DVC6015 instrument: Sliding stem applications
 - 2. DVC6025 instrument: Rotary applications and long stroke sliding stem applications.
 - 3. DVC6035 instrument: Quarter-turn rotary applications
 - ii. DVC6200 remote travel feedback sensor:
 - 1. DVC6215: Sliding stem, rotary, quarter-turn rotary applications

Conclusion

The FIELDVUE DVC6000 series of digital valve controllers have proven to be the most reliable digital valve controllers ever produced. The design philosophy of the DVC6200 and DVC6200f instruments allows the user the flexibility to transition from legacy FIELDVUE products to the current DVC6200 instrument, avoiding lengthy MOC approval documents.

Additional Resources

DVC6200 Product Bulletin (D10415X012)

DVC6200 Instruction Manual (D103605X012)



Visit Fisher.com to find an Emerson sales contact in your area.

f http://www.Facebook.com/FisherValves http://www.Twitter.com/FisherValves

Emerson Automation Solutions

Marshalltown, Iowa 50158 USA Sorocaba, 18087 Brazil Cernay, 68700 France Dubai, United Arab Emirates Singapore 128461 Singapore

http://www.YouTube.com/user/FisherControlValve



http://www.LinkedIn.com/groups/Fisher-3941826

© 2018 Fisher Controls International LLC. All rights reserved.

Fisher and FIELDVUE are marks owned by one of the companies in the Emerson Automation Solutions business unit of Emerson Electric Co. Emerson and the Emerson logo are trademarks and service marks of Emerson Electric Co. All other marks are the property of their respective owners.

The contents of this publication are presented for informational purposes only, and while every effort has been made to ensure their accuracy, nothing herein is to be construed as a warranty or guarantee, express or implied, regarding the products or services described herein or their use, performance, merchantability or fitness for a particular purpose. Individual results may vary. All sales are governed by our terms and conditions, which are available upon request. We reserve the right to modify or improve the designs or specifications of our products at any time without notice. Responsibility for proper selection, use and maintenance of any product or service remains solely with the purchaser and end user.

